

## Classification Report

Number	19-001989-PR04 (NW-A01-02-en-01)
Owner	IALONET - AFOI KONTOU P.C. Kriezi 55 19300 Aspropyrgos Greece
Product	Tripple sliding projecting side-hung casement
Designation	System: FMW92 Shipping name: FMW92 THERMO
Details	Manufacturer IALONET - AFOI KONTOU P.C., - Aspropyrgos; Material Aluminium system with thermal break; Type of opening Sliding-turn; Opening direction Active leaf right side; Overall dimensions (W x H) 2654 mm x 2646 mm
Special features	The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

### Result

Air permeability according to EN 12207:2016-12



**4**

Resistance to wind load according to EN 12210:2016-03




**Class: C3/B3**

Watertightness according to EN 12208:1999-11




**Class: 4A**

ift Rosenheim  
17.12.2019



Robert Kolacny, Dipl.-Ing. (FH)  
Deputy Head of Testing Department  
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.  
Operating Testing Officer  
Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 19-001989-PR04 PB-A01-02-en-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: AC3-9B598