TEST REPORT No. 424315

Customer

KONTOS BROS P.C.

84, Kriezi Str. - 19300 ASPROPYGROS - ATTICA - Greece

Item[#]

parapet named "K1830.170 KINEO 8.4.8"

Activity

resistance to outward horizontal static loading and resistance to 50 kg soft body impact in accordance with standards NF P01-013:1988 and NF P08-301:1991

Results

Activity	Scope	Load	Result
outward horizontal static loading	domestic use	1,3 kN	**compliant**
	public use	1,0 kN/m	**compliant**
50 kg soft body impact	//	//	**compliant**

(#) according to that stated by the customer.

Bellaria-Igea Marina - Italy, 30 December 2024

Chief Executive Officer

(Dott. Arch. Sara Lorenza Giordano)

Firmato digitalmente da SARA LORENZA GIORDANO

Order:
102461

Identification of item received:
2024/3595/A dated 26 November 2024

Activity date:
17 December 2024

Activity site:
Istituto Giordano S.p.A. - Strada Erbosa Uno, 72 - 47043 Gatteo (FC) - Italy

Contents **Page**

Description of item* 2
Normative references 3
Apparatus 3
Method 4
Environmental conditions 4
Results 5
Findings 7

This document is made up of 7 pages and 1 annex and shall not be reproduced except in full without extrapolating parts of interest at the discretion of the customer, with the risk of favoring an incorrect interpretation of the results, except as defined at contractual level.
The results relate only to the item examined, as received, and are valid only in the conditions in which the activity was carried out.
This document extends the validity of all numerical and descriptive data contained in the reference test report.
The original of this document consists of an electronic document digitally signed pursuant to the applicable Italian Legislation.

Chief Test Technician:
Dott. Andrea Bruschi
Head of Security and Safety Laboratory:
Dott. Andrea Bruschi

Compiler: Dott. Marina Bonito